



TEST REPORT
IEC 60947-4-1
Contactors and motor-starters
Electromechanical contactors and motor-starters

Report Number..... : (2018)FQIIDQ-0552

Date of issue..... : 2018-05-16

Total number of pages..... : 206

Applicant's name..... : Zhejiang Tengen Electric Co.,Ltd.

Address..... : Sulv Industry Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Test specification:

Standard..... : IEC 60947-4-1:2009 + A1:2012

Test procedure..... : CB Scheme

Non-standard test method..... : N/A

Test Report Form No..... : IEC60947_4_1B

Test Report Form(s) Originator..... : DEKRA Certification B.V.

Master TRF..... : Dated 2013-07

Copyright © 2013 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description..... : Switch capacitor contactor

Trade Mark..... : TENGEN

Manufacturer..... : Zhejiang Tengen Electric Co.,Ltd./ Sulv Industry Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Model/Type reference..... : TGCC1-25

Ratings..... : Uimp:6kV,Ui:690V;Ith:25A;
 Ue:AC220V/230V,AC380V/400V,AC660V/690V;Ie:17A;
 Utilization category:AC-6b;Us:AC110V,AC220V,AC380V,AC400V,
 AC415V,50Hz;
 AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;
 Qe:7kvar(220V/230V),12kvar(380V/400V),
 18kvar(660V/690V);3P;IP20;
 Matching auxiliary contact:.(noumenon)Ith:10A, 1NO1NC;(Switch
 contactor) Ith:10A,1NO,1NC
 AC-15:380V/0.95A,DC-13:220V/0.15A

Testing procedure and testing location:		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Fujian Inspection and Research Institute for Product Quality(FQII)
Testing location/ address.....:		No. 121, ShanTou Jiao, West Yang Qiao Road, Fuzhou, Fujian,P.R.China
<input type="checkbox"/>	Associated CB Laboratory:	
Testing location/ address.....:		
Tested by (name + signature)		Xie Hongling (Engineer)
Approved by (+ signature)....:		Wei Yunming (Chief Engineer)
		
<input type="checkbox"/>	Testing procedure: TMP	
Testing location/ address.....:		
Tested by (name + signature)....:		
Approved by (+ signature)..... :		
<input type="checkbox"/>	Testing procedure: WMT	
Testing location/ address.....:		
Tested by (name + signature)....:		
Witnessed by (+ signature)..... :		
Approved by (+ signature)..... :		
<input type="checkbox"/>	Testing procedure: SMT	
Testing location/ address.....:		
Tested by (name + signature)....:		
Approved by (+ signature)..... :		
Supervised by (+ signature).....:		