



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006691

Product

Automatic Transfer Switching Equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGQ1N-800L/3,TGQ1N-800M/3,
TGQ1N-800L/4,TGQ1N-800M/4;

Technical data

Ui:800V(main circuit), 400V(auxiliary circuit, control circuit);
Uimp:8kV(main circuit), 2.5kV(auxiliary circuit, control circuit);
Ue:AC400V;Ie: 630A, 700A, 800A;Utilization
Category:AC-33B;Icn: Type L:50kA, Type M:70kA; Icm(peak
value): Type L:105kA, Type M:154kA;ATSE Class:CB;Transfer
mode:ATSE, RTSE;Poles:3P, 4P.

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-19D0064-S, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Apr.16,2020

Valid until: Apr.16,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>