

IEC

IECEE



TM

Ref. Certif. No.

CN54525

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCCB

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGM3-63L, TGM3-63M, TeM5-63L, TeM5-63M;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th
Edition)As shown in the Test Report Ref. No. which
forms part of this Certificate

(2021)FQIIDQ-0748

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.23,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0063707

TGM3-63L, TGM3-63M, TeM5-63L, TeM5-63M;

Uimp:8kV;

Ui: 800V;

Ue:AC380V/400V/415V;

In:10A,15A,16A,20A,25A,30A,32A,40A,50A,60A,63A;

Type of over-current release: Thermal-magnetic, Electro-magnetic;

Type L: Ics:18kA,Icu:25kA;

Type M: Ics:25kA,Icu:35kA;

Selectivity category: A;

3P,3P+N(3 protected poles with an uninterrupted neutral pole),4P;

3P 4P: suitable for isolation; 3P+N: not suitable for isolation;

Matching auxiliary contact:

1NO1NC,2NO2NC,4NO4NC, Uimp:4kV; Ui:500V, Ith:3A,AC-15:380V/0.4A, DC-13:220V/0.15A;

Matching alarm contact:

NO1NC,2NO2NC,4NO4NC, Uimp:4kV;Ui:500V,Ith:3A,AC-15: 380V/0.4A,DC-13:220V/0.15A;

Electronic accessory complying with annex N:

Undervoltage release: Uimp:4kV;Ui:500V Us:AC(220/230/240)V, AC(380/400/415)V,

50HZ;Motor-operator: Uimp:4kV;Ui:500V Us:AC(220/230/240)V,AC(380/400/415)V, 50Hz;

Shunt release with prepayment: Uimp:4kV;Ui:500V Us:AC220V,AC380V, 50Hz

Page 1 of 1

Additional information (if necessary)

Date:

Aug.23,2021

Signature:

谢肇煦

Xie ZhaoXu