





TEST REPORT IEC 60947-2

Low-voltage switchgear and controlgear - Part 2: Circuit-breakers

Report Number.: 03601-A-21CB0152-S

Date of issue: 2022-01-07

Name of Testing Laboratory Suzhou Electrical Apparatus Science Research Institute Co., Ltd.

preparing the Report: (EETI

Applicant's name Zhejiang Tengen Smart Electrics Co. Ltd.

Zhejiang Province, P.R.China

Test specification:

Standard: IEC 60947-2:2016, AMD1:2019

Test procedure....: CB Scheme

Non-standard test method.....: N/A

Test Report Form No.....: IEC60947_2J

Test Report Form(s) Originator....: DEKRA Certification B.V.

Master TRF: Dated 2020-03-31

Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Page 2 of 159

Report No.: 03601-A-21CB0152-S

Test item description: Moulded Case Circuit-Breaker Trade Mark(s): Tengen Zhejiang Tengen Smart Electrics Co., Ltd. Manufacturer....: No. 2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China. Model/Type reference: TGM1NE-630M,TGM1NE-630H,TGMKE-630M,TGMKE-630H, TGMGE-630M,TGMGE-630H,TGMHE-630M,TGMHE-630H Ratings: See page 10 Responsible Testing Laboratory (as applicable), testing procedure and testing location(s): \boxtimes **CB Testing Laboratory:** Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI) No.7 Yonghe Street, Binhe Road, New District, Suzhou, Testing location/ address: China Tested by (name, function, signature): Fang Gang(Team leader) Approved by (name, function, signature) ..: Xu Jianlin(Supervisor) 378304 Testing procedure: CTF Stage 1: Testing location/ address: Tested by (name, function, signature): Approved by (name, function, signature) ..: Testing procedure: CTF Stage 2: Testing location/ address: Tested by (name + signature).....: Witnessed by (name, function, signature).: Approved by (name, function, signature) ..: **Testing procedure: CTF Stage 3: Testing procedure: CTF Stage 4:** Testing location/ address: Tested by (name, function, signature): Witnessed by (name, function, signature).: Approved by (name, function, signature) ..: Supervised by (name, function, signature):

Report No.: 03601-A-21CB0152-S

List of Attachments (including a total number of pages in each attachment):	
Attachment 1: photos of the product (pages 5,159)	
Summary of testing:	
In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:	
☐ Programme 1 (three pole fully tested)	
□ Programme 2 (four pole fully tested)	
☐ Alternative program not applicable	
Tests performed (name of test and test clause):	Sample No.:##21#22 Mechanical properties of terminals 8.2.4
TEST SEQUENCE I	Clearances and creepage distances 7.1.4
Sample No.:#01#02	Insulating material: Comparative tracking index 7.1.4
8.3.3 General performance characteristics	Resistance to abnormal heat and fire 8.2.1.1.1
'	resistance to disnormal meditaria in 6 s.z. i. i. i
TEST SEQUENCE II (Ics)	Sample specifications:
Sample No.:#03-#10	TGM1NE-630MP 630A 4P #01
8.3.4 Rated service short-circuit breaking capacity	TGM1NE-630M 630A 3P #02
TECT OF OUTNOE III (Ic.)	TGMHE-630M/3300 630A 3P #03#04#05#20#21#22
TEST SEQUENCE III (Icu) Sample No.:#11-#15	TGMHE-630M/3300 400A 3P #06#26
8.3.5 Rated ultimate short-circuit breaking capacity	TGMKE-630M/3300 630A 3P
o.o.o realed ditimate short-circuit breaking capacity	#11#12#13#17#27
TEST SEQUENCE III (phase+N test)	TGMKE-630M/3300 400A 3P #14#18 TGMGE-630H/3300 630A 3P #07#08#09
Sample No.:#16	TGMGE-630H/3300 630A 3P #07#06#09
	TGMKE-630M/4300 630A 4P#15#16#19#23
TEST SEQUENCE IV	TGM1NE-630 with communication
Sample No.:#17#18	module+overload non-tripping accessory
8.3.6 Rated short-time withstand current	#24#25 TGMHE-630M/3300 400A 3P #26
TEST SEQUENCE IV (phase+N test)	TGMKE-630M/3300 630A 3P #27
Sample No.:#19	
Annex C -Individual pole short-circuit test sequence	Remark:
Sample No.:#26#27	This test report is based on test report 03601-A-
r. F	21B0977-S issued on 2021-11-19, all the test
Annex F - Additional tests for circuit-breakers with	results are copied from the test report(except
electronic over-current protection	CTI test).
Sample No.:#20#23	
Appear N. Flootreme quetic competibility (FMC)	
Annex N- Electromagnetic compatibility (EMC) Sample No.:#24#25	
Testing location:	
-	
No.7 Yonghe Street, Binhe Road, New District, Suzhou, China	
Summary of compliance with National Differences (List of countries addressed):	
N/A	

Page 4 of 159 Report No.: 03601-A-21CB0152-S

Statement concerning the uncertainty of the measurement systems used for the tests (may be required by the product standard or client)
☐ Internal procedure used for type testing through which traceability of the measuring uncertainty has been established: Procedure number, issue date and title:
Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.