



TEST REPORT IEC 60947-2 Low-voltage switchgear and controlgear - Part 2: Circuit-breakers

Report Number:	03601-A-21CB0151-S	
Date of issue:	2022-01-07	
Total number of pages	155 pages	
Name of Testing Laboratory preparing the Report:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd. (EETI)	
Applicant's name:	Zhejiang Tengen Smart Electrics Co., Ltd.	
Address:	No. 2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China.	
Test specification:		
Standard:	IEC 60947-2:2016, AMD1:2019	
Test procedure:	CB Scheme	
Non-standard test method:	N/A	
Test Report Form No:	IEC60947_2J	
Test Report Form(s) Originator :	DEKRA Certification B.V.	
Master TRF:	Dated 2020-03-31	

$Copyright @ 2020 \ \mbox{IEC System of Conformity Assessment Schemes for Electrotechnical Equipment} and Components (IECEE System). \ \mbox{All rights reserved}.$

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description:	Moulded Case Circuit-Breaker
Trade Mark(s):	Tengen
Manufacturer: Model/Type reference:	Zhejiang Tengen Smart Electrics Co., Ltd. No. 2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China. TGM1NE-800M,TGM1NE-800H,TGMKE-800M,TGMKE-800H, TGMGE-800M,TGMGE-800H,TGMHE-800M,TGMHE-800H
Ratings:	See page 10

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
\boxtimes	CB Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
Testir	ng location/ address:	No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
Teste	d by (name, function, signature) :	Fang Gang(Team leader)
Appro	oved by (name, function, signature) :	Xu Jianlin(Supervisor) 子本また
	Testing procedure: CTF Stage 1:	
	resting procedure. OTP Stage 1.	
Testin	ng location/ address:	

Tested by (name, function, signature):	
Approved by (name, function, signature) :	

	Testing procedure: CTF Stage 2:	
Testii	ng location/ address:	
Tosto	d by (name + signature):	
Teste	u by (fiame + signature)	
Witne	ssed by (name, function, signature). :	
Appro	oved by (name, function, signature):	

~

TRF No. IEC60947_2J

Summary of testing:	
In case of alternative test programs for circuit bre following program is used:	akers with a different number of poles, the
Programme 1 (three pole fully tested)	
☑ Programme 2 (four pole fully tested)	
Alternative program not applicable	
Tests performed (name of test and test clause):	Sample No.:##21#22
resis performed (name of test and test clause).	Mechanical properties of terminals 8.2.4
	Clearances and creepage distances 7.1.4
	Insulating material:
Sample No.:#01#02	Comparative tracking index 7.1.4
3.3.3 General performance characteristics	Resistance to abnormal heat and fire 8.2.1.1.1
TEST SEQUENCE II (Ics)	Sample specifications:
Sample No.:#03-#10	TGM1NE-800MP 800A 4P #01
8.3.4 Rated service short-circuit breaking capacity	TGM1NE-800M 800A 3P #02
	TGMHE-800M/3300E2 800A 3P #03#04#05
TEST SEQUENCE III (Icu)	TGMHE-800M/3300E2 630A 3P #06
Sample No.:#11-#15	TGMKE-800M/3300E2 800A 3P
8.3.5 Rated ultimate short-circuit breaking capacity	#11#12#13#17#20#21#22#25
5 1 3	TGMKE-800M/3300E2 630A 3P #14#18#26
TEST SEQUENCE III (phase+N test)	TGMGE-800H/3300E2 800A 3P #07#08#09 TGMGE-800H/3300E2 630A 3P #10
Sample No.:#16	TGMKE-800M/4300CE2 800A 4P #15#16#19
·	TGM1NE-800 with communication
TEST SEQUENCE IV	module+overload non-tripping accessory #23#2
Sample No.:#17#18	11 5 ,
8.3.6 Rated short-time withstand current	
	Remark:
TEST SEQUENCE IV (phase+N test)	This test report is based on test report 03601-A
Sample No.:#19	21B0976-S issued on 2021-11-19, all the test
	results are copied from the test report(except
Annex C -Individual pole short-circuit test sequence	CTI test).
Sample No.:#25#26	
Annex F - Additional tests for circuit-breakers with	
electronic over-current protection	
Sample No.:#20	
Annex N- Electromagnetic compatibility (EMC)	
Sample No.:#23#24	

Summary of compliance with National Differences (List of countries addressed):

N/A

Statement concerning the uncertainty of the measurement systems used for the tests (may be required by the product standard or client)

☐ Internal procedure used for type testing through which traceability of the measuring uncertainty has been established:

Procedure number, issue date and title:

Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.

 \boxtimes Statement not required by the standard used for type testing