



Test Report issued under the responsibility of:



**TEST REPORT**  
**IEC 60947-2**

**Low-voltage switchgear and controlgear - Part 2: Circuit-breakers**

Report Number. .... : 03601-A-21CB0150-S

Date of issue ..... : 2022-04-20

Total number of pages ..... : 153 pages

Name of Testing Laboratory  
preparing the Report ..... : Suzhou Electrical Apparatus Science Research Institute Co., Ltd.  
(EETI)

Applicant's name ..... : Zhejiang Tengen Smart Electrics Co., Ltd.

Address ..... : No. 2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China.

**Test specification:**

Standard ..... : IEC 60947-2:2016, AMD1:2019

Test procedure ..... : CB Scheme

Non-standard test method ..... : N/A

Test Report Form No. .... : IEC60947\_2J

Test Report Form(s) Originator .... : DEKRA Certification B.V.

Master TRF ..... : Dated 2020-03-31

**Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

**General disclaimer:**

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

<b>Test item description .....</b>	Moulded Case Circuit-Breaker	
<b>Trade Mark(s) .....</b>	Tengen	
<b>Manufacturer .....</b>	Zhejiang Tengen Smart Electrics Co., Ltd. No. 2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China.	
<b>Model/Type reference .....</b>	TGM1NE-1250M, TGM1NE-1250H, TGMKE-1250M, TGMKE-1250H, TGMGE-1250M, TGMGE-1250H, TGMHE-1250M, TGMHE-1250H	
<b>Ratings .....</b>	See page 10	
<b>Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):</b>		
<input checked="" type="checkbox"/>	<b>CB Testing Laboratory:</b>	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
<b>Testing location/ address .....</b>		No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
<b>Tested by (name, function, signature) .....</b>		Fang Gang(Team leader) 方刚
<b>Approved by (name, function, signature) ..</b>		Xu Jianlin(Supervisor) 许建林
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 1:</b>	
<b>Testing location/ address .....</b>		
<b>Tested by (name, function, signature):</b>		
<b>Approved by (name, function, signature) ..</b>		
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 2:</b>	
<b>Testing location/ address .....</b>		
<b>Tested by (name + signature).....</b>		
<b>Witnessed by (name, function, signature) . :</b>		
<b>Approved by (name, function, signature) .. :</b>		
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 3:</b>	
<input type="checkbox"/>	<b>Testing procedure: CTF Stage 4:</b>	
<b>Testing location/ address .....</b>		
<b>Tested by (name, function, signature):</b>		
<b>Witnessed by (name, function, signature) . :</b>		
<b>Approved by (name, function, signature) .. :</b>		
<b>Supervised by (name, function, signature) :</b>		

<b>List of Attachments (including a total number of pages in each attachment):</b> Attachment 1: photos of the product (page 5,153)	
<b>Summary of testing:</b>  <b>In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:</b> <input type="checkbox"/> Programme 1 (three pole fully tested) <input checked="" type="checkbox"/> Programme 2 (four pole fully tested) <input type="checkbox"/> Alternative program not applicable	
<b>Tests performed (name of test and test clause):</b>  TEST SEQUENCE I Sample No.:#01#02 8.3.3 General performance characteristics  TEST SEQUENCE II (Ics) Sample No.:#03-#10 8.3.4 Rated service short-circuit breaking capacity  TEST SEQUENCE III (Icu) Sample No.:#11-#15 8.3.5 Rated ultimate short-circuit breaking capacity  TEST SEQUENCE III (phase+N test) Sample No.:#16  TEST SEQUENCE IV Sample No.:#17#18 8.3.6 Rated short-time withstand current  TEST SEQUENCE IV (phase+N test) Sample No.:#21  Annex C -Individual pole short-circuit test sequence Sample No.:#19#20  Annex F - Additional tests for circuit-breakers with electronic over-current protection Sample No.:#22#24  Annex N- Electromagnetic compatibility (EMC) Sample No.:#25	Sample No.:##23#24 Mechanical properties of terminals 8.2.4 Clearances and creepage distances 7.1.4 Insulating material: Comparative tracking index 7.1.4 Resistance to abnormal heat and fire 8.2.1.1.1  Sample specifications: TGM1NE-1250MP/4340CE3 1250A 4P #01 TGM1NE-1250M/3338III E3 1250A 3P #02 TGMHE-1250M/3300E3 1250A 3P #03#04#05#19 TGMHE-1250M/3300E3 800A 3P #06#20 TGMKE-1250M/3300E3 1250A 3P #11#12#13#17#22#23#24 TGMKE-1250M/3300E3 800A 3P #14#18 TGMGE-1250H/3300E3 1250A 3P #07#08#09 TGMGE-1250H/3300E3 800A 3P #10 TGMKE-1250M/4300CE3 1250A 4P #15#16#21 TGMGE-1250 with electric operator AC240V+ undervoltage AC240V #25  Remark: This test report is based on test report 03601-A-21B0975-S issued on 2022-01-19, all the test results are copied from the test report(except CTI test).
<b>Testing location:</b> No.7 Yonghe Street, Binhe Road, New District, Suzhou,China	
<b>Summary of compliance with National Differences (List of countries addressed):</b>  <b>N/A</b>	