Test Report issued under the responsibility of:



## TEST REPORT EN IEC 60947-4-1 Low voltage switchgear and controlgear Part 4: Contactors and motor-starters Section 1 - Electromechanical contactors and motor-starters

Report Number	03601-A-22D0157-S-A
Date of issue:	2023-04-03
Total number of pages:	135 pages
Name of Testing Laboratory preparing the Report:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd. (EETI)
Applicant's name:	Zhejiang Tengen Electric Co., Etd
Address:	Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Test specification:	
Standard	EN IEC60947-4-1:2019
Test procedure	CCA Scheme
Non-standard test method:	N/A
Test Report Form No:	EN IEC 60947_4_1D
Test Report Form(s) Originator:	DEKRA Certification B.V.
Master TRF	Dated 2019-05-14

Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

## **General disclaimer:**

The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description:	AC Contactor
Trade Mark:	TENGEN
Manufacturer:	Zhejiang Tengen Electric Co., Ltd.
1.3	Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Model/Type reference:	See page 5
Ratings:	See page 5

## Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):

$\boxtimes$	Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd. (EETI)
Testi	ng location/ address:	No.7 Yonghe Street, Binhe Road, New District, Suzhou, China
Teste	ed by (name, function, signature) :	Fang Gang (Team leader)
Appr	oved by (name, function, signature) :	Xu Jianlin (Supervisor)
	Testing procedures CTE Stone 1	
	Testing procedure: CTF Stage 1:	(
Testi	ng location/ address:	
Test	ed by (name, function, signature) :	
Appr	oved by (name, function, signature) :	
	Testing procedure: CTF Stage 2:	
Testi	ng location/ address:	
Teste	ed by (name + signature):	
Witne	essed by (name, function, signature). :	
Appr	oved by (name, function, signature) :	
	Testing procedure: CTF Stage 3:	
	Testing procedure: CTF Stage 4:	
Testi	ng location/ address :	
Test	ed by (name, function, signature) :	
Witn	essed by (name, function, signature). :	
Appr	oved by (name, function, signature) :	
Supe	ervised by (name, function, signature) :	

TRF No. EN IEC 60947\_4\_1D

Summary of testing:	
Tests performed (name of test and test clause): Test sequence I: - Temperature rise (Clause 9.3.3.3) #01#02#03	Sample specifications: TGC1-3811x Us: 415V 50/60Hz:#01#23#2
<ul> <li>Temperature rise (Clause 9.3.3.3) #01#02#03</li> <li>Operating limits (Clause 9.3.3.2) #03~#18</li> <li>Test of dielectric properties (Clause 9.3.3.4) #03</li> <li>Coil power consumption(Clause 9.3.3.2.1.2) #01#03#04#23#24</li> <li>Pole impedance(Clause 9.3.3.2.1.3) #23</li> </ul>	TGC1-3211x Us: 415V 50/60Hz: #02#21#22 TGC1-2511x Us: 415V 50/60Hz: #03#19#20#31#32 TGC1-2511x Us: AC24V 50Hz: #04 TGC1-2511x Us: AC36V 50Hz: #05
Test sequence II: #19~#30 - Making and breaking capacity (Clause 9.3.3.5) - Operational performance capability (Clause 9.3.3.6)	TGC1-2511x Us: AC48V 50Hz: #06 TGC1-2511x Us: AC110V 50Hz: #07 TGC1-2511x Us: AC220V 50Hz: #08 TGC1-2511x Us: AC380V 50Hz: #09
Test sequence III: - Test at the prospective current "r" (Clause 9.3.4.2.2) #31	TGC1-2511x Us: AC400V 50Hz: #10 TGC1-2511x Us: AC415V 50Hz: #11
- Test at the rated conditional short-circuit current "Iq" (Clause 9.3.4.2.3) #32	TGC1-2511x       Us: AC24V       50/60Hz: #12         TGC1-2511x       Us: AC36V       50/60Hz: #13         TGC1-2511x       Us: AC48V       50/60Hz: #14
Test sequence IV - Overload current withstand capability of contactors (Clause 9.3.5) #33#34#35	TGC1-2511x       Us: AC110V       50/60Hz: #15         TGC1-2511x       Us: AC220V       50/60Hz: #16         TGC1-2511x       Us: AC380V       50/60Hz: #17         TGC1-2511x       Us: AC400V       50/60Hz: #18
Test sequence V: #36#37 -Verification of mechanical properties of terminals (8.2.4) -Verification of degree of protection (Annex C)	TGC1-2511xN Us: 415V 50/60Hz: #25#26 TGC1-3211xN Us: 415V 50/60Hz: #27#26 TGC1-3811xN Us: 415V 50/60Hz: #29#30
EN60947-1: #01#03 Clearances and creepage distances (Clause 8.1.4) Comparative tracking index (Clause 8.1.4) Resistance to abnormal heat and fire (Clause 8.2.1.1.1)	TGC1-2511: Us: AC24V(50Hz): #33 TGC1-3211: Us: AC110V(50/60Hz): #34 TGCG-3811: Us: AC220V(50Hz): #35#40#41 TGC1-3211: Us: AC415V(50/60Hz): #36
For auxiliary circuits, please refer to report 03601-A- 22D0157-S-B #38#39#40#41	TGC1-2511: Us: AC415V(50Hz): #37 TGC1-3211: Us: AC48V(50/60Hz): #38 TGC1-3211: Us: AC36V(50/60Hz): #39
Remark: This test report is based on test report 03601-A- 22B0876-S issued on 2022-11-25, all the test results are copied from the test report(except CTI test).	
Testing location:	
Suzhou Electrical Apparatus Science Research Institute C	
No.7 Yonghe Street, Binhe Road, New District, Suzhou, C	hina