



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006914-A1

Product

Automatic Transfer Switching Equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGQ1NPL-630,TGQKPL-630;

Technical data

Ui:800V(main circuit);500V(control and auxiliary
circuits);Ith: 630A;Uimp:8kV(main circuit);4kV(control and
auxiliary circuits);Ue: AC230V(2P),AC400V(3P,4P);Ie:
250A,315A,350A,400A,500A,630A;Utilization
Category:AC-33B;Icm: 40kA; Icw:
20kA/60ms;Iq:120kA;Class of equipment: PC;Method of
controlling:ATSE;2P, 3P, 4P.

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-23D0065-S-A1, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jul.19,2023

Valid until: Jul.18,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE