

# IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Moulded case circuit breaker

Name and address of the applicant

Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

Name and address of the manufacturer

Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic  
Development Zone Branch) No.288 Central Avenue Development  
Zone, Yueqing City,  
325604 Zhejiang  
P.R. China

Ratings and principal characteristics

Cat A; Ue: 230V ~ (1P), 400V~ (2P/3P/4P), 50/60Hz;  
Ue: DC80V(1P), DC125V(2P); Ui:1000V; Uimp:6kV;  
In/Ith:1/2/3/4/5/6/10/16/20/25/32/40/50/63A;  
B type:Ii=4In±20%, C type:Ii:8In±20%,D type:Ii=12In±20%;  
AC:Icu=10kA, Ics=7.5kA;  
DC:Icu=10kA, Ics=10kA

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGB3Z-63H

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN22DOKQ 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com



Date: 2022-08-30

Signature:

Wencai Zhang