CE CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230303008580

Product	МССВ
Applicant	Zhejiang Tengen Electric Co.,Ltd.
	Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Type/Model	TGM3-400L,TGM3-400M,TGM3-400H;
Technical data	See the Appendix
This is to certify that, on the basis of the tests undertaken as per Report No.	
E T	he submitted sample(s) of the above item complies with:
EN	60947-2:2017/A1:2020;EN 60947-2:2017
and fulfills testing requirements of the European Directive:	
	2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Nov.17,2023

Valid until: Nov.16,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn





CHINA QUALITY CERTIFICATION CENTRE

http://www.cqc.com.cn

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

CE CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230303008580

TGM3-400L,TGM3-400M,TGM3-400H; Uimp:8kV;Ui: 800V; Ue:AC400/690V; In: 225A,250A, 315A,350A,400A; Type of over-current release: Thermo-magnetic, Electro-magnetic; 400V:Type L:lcs:35kA,lcu:50kA; Type M:lcs:65kA,lcu:65kA; Type H:lcs:65kA,lcu:85kA; 690V:Type L:lcs:10kA,lcu:15kA; Type M:Ics:20kA,Icu:20kA; Type H:lcs:20kA,lcu:30kA; Selectivity category:A; 3P,3P+N(Type A:3 protected poles with an uninterrupted neutral pole; Type D:3 protected poles with a protected uninterrupted neutral pole); 4P(Type B:3 protected poles with a switched neutral pole; Type C:4 protected poles); 3P,4P:Suitable for isolation; 3P+N:Not suitable for isolation; Matching auxiliary contact:FC38-400, 1NO1NC,2NO2NC,4NO4NC;Ith:6A; AC-15:(380/400)V/1A; DC-13:(220/230)V/0.15A; Electronic accessory complying with annex N: Undervoltage release:QT38-400, Us:AC(220/230)V,AC(380/400)V; Motor-operator: CD2-400, Us:AC(220/230)V,AC(380/400)V



Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China