



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008870

**Product**

Plastic case circuit breaker

**Applicant**

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model**

TGM1-800L,TGM1-800M,TGMNR-800L,TGMNR-800M

**Technical data**

See attachment

This is to certify that, on the basis of the tests undertaken as per Report No.  
00901-CE2022CQC0303-012868, the submitted sample(s) of the above item complies  
with:

**EN 60947-2:2017/A1:2020;EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only,  
and does not include the manufacturing process. Users shall affix the mark in accordance  
with the related legislation.

**Valid from: May.13,2024**

**Valid until: May.12,2027**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

## CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240303008870

TGM1-800L,TGM1-800M,TGMNR-800L,TGMNR-800M;

Ui:800V;

Uimp: 8kV;

Ue: AC400/415V,AC660/690V;

In: 630A、700A、800A;

Over-current release:Thermo-magnetic;

Ics:

Type L: 35kA/AC400/415V, 15kA/AC660/690V

Type M: 37.5kA/AC400/415V, 15kA/AC660/690V

Icu:

Type L: 50kA/AC400/415V, 30kA/AC660/690V

Type M: 75kA/AC400/415V, 30kA/AC660/690V

Selectivity category:A;

Poles: 3P, 3P+N(3 protected poles with an uninterrupted neutral pole),4P(3 protected poles with a switched neutral pole) ,4P;

Applicable for isolation(except 3P+N);

Tripclass com.cqc.cms.component.word.CertiAnnexDataModel:10;

Auxiliary contact, alarm contact:2NO2NC;

Ui:690V;Uimp:4kV;lth:3A;

AC-15:Ue/Ie:AC380V/0.4A;

DC-13:Ue/Ie:DC220V/0.15A;

Accessories with electronic circuits:

Motor-operator:CD3-800/M:Us: AC220/AC230V,AC380V/AC400V;

Undervoltage release: 800QT:Us:AC220V,AC380



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE